

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9062705

Reedsport School District 105
 100 Ranch Road
 Reedsport, OR 97467

Project: General
 Project #: Lead 2019/Reedsport School District
 Office
 Client Contact: Jon Zwemke

Date Reported: 07/08/19
 Date Received: 06/27/19 13:00
 Sampled By: Thomas Capps

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
9062705-01	Sample Location: LUH Staff									
Lead		1030	ND	ppb	2	20	06/27/19 05:30	06/28/19	JJL	
Copper			403	ppb	10	1300	06/27/19 05:30	06/28/19	JJL	
9062705-02	Sample Location: LUH Bath									
Lead		1030	ND	ppb	2	20	06/27/19 05:32	07/01/19	JJL	
Copper			294	ppb	10	1300	06/27/19 05:32	07/01/19	JJL	
9062705-03	Sample Location: DO Kitchen									
Lead		1030	11	ppb	2	20	06/27/19 05:35	07/01/19	JJL	
Copper			80	ppb	10	1300	06/27/19 05:35	07/01/19	JJL	
9062705-04	Sample Location: DO Server									
Lead		1030	5	ppb	2	20	06/27/19 05:35	07/01/19	JJL	
Copper			286	ppb	10	1300	06/27/19 05:35	07/01/19	JJL	
9062705-05	Sample Location: DO Mens Room									
Lead		1030	16	ppb	2	20	06/27/19 05:36	07/01/19	JJL	
Copper			832	ppb	10	1300	06/27/19 05:36	07/01/19	JJL	
9062705-06	Sample Location: DO Womens Room									
Lead		1030	27	ppb	2	20	06/27/19 05:38	07/01/19	JJL	CON-1
Copper			633	ppb	10	1300	06/27/19 05:38	07/01/19	JJL	
9062705-07	Sample Location: Day Care Laundry									
Lead		1030	ND	ppb	2	20	06/27/19 05:40	07/01/19	JJL	
Copper			531	ppb	10	1300	06/27/19 05:40	07/01/19	JJL	
9062705-08	Sample Location: Day Care RR 1									
Lead		1030	ND	ppb	2	20	06/27/19 05:42	07/01/19	JJL	
Copper			629	ppb	10	1300	06/27/19 05:42	07/01/19	JJL	
9062705-09	Sample Location: Day Care RR #2									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Alyssa Williams, Quality Assurance Officer



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9062705

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	ppb	2	20	06/27/19 05:44	07/01/19	JJL	
Copper			522	ppb	10	1300	06/27/19 05:44	07/01/19	JJL	
9062705-10	Sample Location: Day Care RR #3									
Lead		1030	ND	ppb	2	20	06/27/19 05:45	07/01/19	JJL	
Copper			524	ppb	10	1300	06/27/19 05:45	07/01/19	JJL	
9062705-11	Sample Location: Day Care Kitchen #1									
Lead		1030	ND	ppb	2	20	06/27/19 05:47	07/01/19	JJL	
Copper			480	ppb	10	1300	06/27/19 05:47	07/01/19	JJL	
9062705-12	Sample Location: Day Care Kitchen #2									
Lead		1030	2	ppb	2	20	06/27/19 05:48	07/01/19	JJL	
Copper			322	ppb	10	1300	06/27/19 05:48	07/01/19	JJL	
9062705-13	Sample Location: FRC RR Sink									
Lead		1030	ND	ppb	2	20	06/27/19 05:50	07/01/19	JJL	
Copper			768	ppb	10	1300	06/27/19 05:50	07/01/19	JJL	
9062705-14	Sample Location: FRC Kitchen									
Lead		1030	24	ppb	2	20	06/27/19 05:53	07/01/19	JJL	CON-1
Copper			800	ppb	10	1300	06/27/19 05:53	07/01/19	JJL	
9062705-15	Sample Location: Day Care Shower									
Lead		1030	9	ppb	2	20	06/27/19 05:55	07/01/19	JJL	
Copper			775	ppb	10	1300	06/27/19 05:55	07/01/19	JJL	
9062705-16	Sample Location: FRC Janitor									
Lead		1030	20	ppb	2	20	06/27/19 06:00	07/01/19	JJL	CON-1
Copper			1317	ppb	10	1300	06/27/19 06:00	07/01/19	JJL	CON-1

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Alyssa Williams, Quality Assurance Officer



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 9062705

Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Alyssa Williams, Quality Assurance Officer